




**CSA  
Group**

1707 – 94<sup>th</sup> Street NW  
Edmonton, Alberta, Canada  
T6N 1E6  
Tel: (780) 450-2111  
Fax: (780) 461-5322  
Website: www.csagroup.org

<b>TEST REPORT</b> <b>PERFORMANCE TESTING/EVALUATION IN ACCORDANCE WITH</b> <b>NAFS-AAMA/WDMA/CSA 101/I.S.2/A440-2008/2011 and CSA A440S1-09/17</b>	
<b>Product manufacturer</b> .....: Churchill Interiors Ltd. <b>Address</b> .....: 48007 232 Ave E .....: Foothills, AB, T1S 5C4 <b>Attention</b> .....: Mr. Ronald Hanoski <b>Report Reference No</b> .....: 70134979 <b>Date of issue</b> .....: November 27 , 2017 <b>Test Completion Date</b> .....: November 10 , 2017 <b>Total number of pages</b> .....: 6	
<b>Test Report Summary:</b> <b>Product Type</b> .....: Inswing Door with Sidelites and Transom <b>Product Series/Model</b> .....: 96" x 112" Inswing Door with Sidelites and Transom (overall) <b>Primary Product Designator</b> .....: Class R – PG15 - Size tested 2438 mm x 2845 mm <b>Secondary Product Designator</b> .....: Positive Design Pressure (DP) = 720 Pa (15.04 psf) Negative Design Pressure (DP) = -720 Pa (15.04 psf) Water Penetration Resistance Test Pressure = 220 Pa (4.95 psf) Canadian Air Infiltration/Exfiltration = A3 Level	
<b>Prepared By</b> Name: Adrian Zilahi Title: Certifier  Signature: 	<b>Approved By</b> Name: Mohamadou L. Diallo Title: Certifier  Signature: 